

Plan Review Summary

Building Information

Project Name:	Woodruff Residence Kitchen Hood Retrofit	Floor/Room #:	All floors 02 stack
Building #:	166N&116S	Department:	Housing O&M
Occupancy Type:	Dormitory	Budget:	\$80,000
Construction Type:	IIB	Type of Review:	Fire Suppression-ASBUILTS

Project Management

Project Manager:	Fred Holder
Architect/Engineer of Record:	Mike Bowling
Construction Manager:	
Aim Project Number:	20-276200

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/22/2020
Disposition:	Declined	Date Completed:	5/26/2020

Status Statement

Note: Addition of Guardian Suppression systems to all kitchen stoves

Review Comments:

1. Please confirm that all hoods will be tied into existing fire alarm system
2. Please confirm fire alarm system can handle additional points
3. Submit fire alarm battery calcs to show compliance

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, balloon test of system, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm