
Plan Review Summary

Building Information

Project Name:	Campus Center Phase 1-Cafe AS BUILTS	Floor/Room #:	
Building #:	215	Department:	Facilities-Design & Construction
Occupancy Type:	Business	Budget:	\$110M
Construction Type:	IIB	Type of Review:	Construction-AS BUILTS

Project Management

Project Manager:	John DuConge
Architect/Engineer of Record:	Cooper Carry
Construction Manager:	Gilbane Building Company
Aim Project Number:	BOR-PPV-30-1801

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/22/2020
Disposition:	Declined	Date Completed:	5/28/2020

Status Statement

Note: Fire Alarm; Electrical; and Fire Sprinkler As-builts

Review Comments:

1. Fire alarm as-builts, Electrical As-builts, and fire sprinkler As-builts were all submitted under one plan review letter. Fire alarm and fire sprinkler systems each are required a separate permit as well as the electrical. Please submit all three sets of plans separately to each include their own plan review letter.
 2. Fire alarm as-builts are required a central station testing report from Georgia Security indicating each device has been tested and that each devices address point (L1N1D1 for example) is listed in the report, so verification with the Riser diagram can be reviewed and approved.
 1. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)
-