
Plan Review Summary

Building Information

Project Name:	Campus Services Warehouse CO Work(Fire Alarm)	Floor/Room #:	Suites 100, 200, 400, 500 & 600
Building #:	882	Department:	Housing
Occupancy Type:	Business	Budget:	\$137,225.00
Construction Type:	IIIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Jeffrey Juliano
Construction Manager:	
Aim Project Number:	0207-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/2/2020
Disposition:	Declined	Date Completed:	6/4/2020

Status Statement

Note: Campus Services Fire Alarm modify for tenant layout

Review Comments:

1. Construction Type was not identified
2. Occupancy type was not identified
3. Points of reference not identified
4. Page FP1; Notification devices shall be white bases as required in the Yellow Book Standard
5. Page FP1: #9 – Strobes that are in visual range shall sync not just in the common areas.
6. All alarm testing and pretesting must notify occupants with 24 hours of testing. Signage must be picked up from the Fire Safety Office on the 48 hours before testing actually occurs.
7. Commissioning of the alarm system will require as-builts to be submitted with alarm points from the central station monitoring company.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Permits Required:

1. Fire Alarm
-