
Plan Review Summary

Building Information

Project Name:	1797 CRB Exterior Renovations	Floor/Room #:	Roof/Exterior
Building #:	790	Department:	GTRI SSD
Occupancy Type:	Business	Budget:	
Construction Type:	IIIB	Type of Review:	Logistics-Crane Plan

Project Management

Project Manager:	Michelle Doyle
Architect/Engineer of Record:	
Construction Manager:	Rebekah Snider
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/12/2020
Disposition:	Declined	Date Completed:	6/15/2020

Status Statement

Note: Crane Plan letter

Review Comments:

1. Provide recent inspection record for the crane and cable
2. Provide crane specifications
3. Provide layout of where crane will be located on campus
4. Provide "No Fly Zone"
5. Provide operators credentials including driver's license
6. Provide safety plan for protection of students, staff and visitors.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting

Permits Required:

1. Crane Plan Letter of Approval
-