
Plan Review Summary

Building Information

Project Name:	1747 CCRF B12 ELSYS Open Lab Renovation	Floor/Room #:	1st Floor
Building #:	763	Department:	SSD
Occupancy Type:	Business	Budget:	\$430,000
Construction Type:	IIIA	Type of Review:	Construction

Project Management

Project Manager:	Nic Palfrey
Architect/Engineer of Record:	Dennis Carter
Construction Manager:	Richard Whitehead
Aim Project Number:	0212-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/24/2020
Disposition:	Declined	Date Completed:	7/2/2020

Status Statement

Note: Interior renovation of B12 ELSYS Open Lab

Review Comments:

1. Occupancy classification is incorrect and needs changed per IBC, IFC, NFPA 101
2. Page LS-1: Define the lab classification
3. Page LS-1: Wrong code references (All codes and GA Amendments)
4. Page LS-1: (GT Standard) Drawings to wrong scale
5. FP-1 Separate submittal and permit
6. P1: Supply specs on new piping being used
7. E-4: Separate submittal and permit

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Permits Required:

1. Construction / Interior Renovation
 2. Fire Suppression System
 3. Fire Alarm
-