
Plan Review Summary

Building Information

Project Name:	IBB Interconnect Standby Power Design	Floor/Room #:	Basement North Interconnect
Building #:	146	Department:	OIT
Occupancy Type:	Business	Budget:	\$250,000
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Tony Gonzalez
Architect/Engineer of Record:	Dennis Carter
Construction Manager:	Blake Baklini
Aim Project Number:	0121-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/26/2020
Disposition:	Declined	Date Completed:	7/6/2020

Status Statement

Note: Emergency Generator replacement

Review Comments:

1. Main page, code references are incorrect including Georgia Amendments
2. Drawings not to scale (GT= 1/8"=1'0)
3. Occupancy type not defined
4. Supply cut sheets for all equipment
5. NFPA 110 also needs to be addressed
6. If gas supply piping specs

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
 2. Fire Alarm
-