
Plan Review Summary

Building Information

Project Name:	Ford ES&T Naif Lab Fit-Up	Floor/Room #:	First Floor/1235
Building #:	147	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	D&C, Ngugi Mathu
Construction Manager:	Blake Baklini
Aim Project Number:	0396-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/1/2020
Disposition:	Declined	Date Completed:	7/7/2020

Status Statement

Note: Changing Computer lab to a storage/workshop lab

Review Comments:

1. Supply dimensions on shelves (heights) IFC – Maintain minimum 18” below sprinkler deflector
2. Soldering area shall be isolated from rest of area and shall be identified on plan
3. Confirm sprinkler coverage correct for new lab

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Permits Required:

1. Construction / Interior Renovation
 2. Fire Suppression System
 3. Fire Alarm
-