Plan Review Summary

Georgia Environmental Tech Health & Safety

Fire Safety

151 Sixth Street, Suite 341

Atlanta, Georgia 30332 404-894-FIRE (3473)

Building Information			
Project Name:	CEE USDA Waste Water Pilot Project	Floor/Room #:	
Building #:	800	Department:	COE
Occupancy Type:	Business	Budget:	\$600,000
Construction Type:	VA	Type of Review:	Construction-REVISION
Project Management			
Project Manager:	Jerry Young		
Architect/Engineer of	Record: J. Weckerley/B. Oswell		
Construction Manage	er: Jerry Young		
Aim Project Number:	0211-2019		
Reviewer Information			
Reviewer Name:	Jerry Marrison	Date Received:	7/1/2020
Disposition:	Declined	Date Completed:	7/7/2020
Status Statement			
Note: Office for wastewater treatment			
Review Comments:			
 NFPA 704 – 4.3 – Supply appropriate warning placard meeting the 704 standards GT Standard – Knox Box 4400 Series required Fire alarm required (minimum 2 smokes, 1 pull station) Fire alarm and DGMS must communicate and communicate to alarm monitoring company Portable fire extinguisher required 			
General Note:			
 Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work 			

Plan / Shop Drawings Required:

1. Fire Alarm

Permits Required:

- 1. Construction / Interior Renovation
- 2. Fire Alarm