
Plan Review Summary

Building Information

Project Name:	Women's Basketball Locker Room Renovations	Floor/Room #:	1st floor, locker, lounge
Building #:	73A	Department:	GT D&C
Occupancy Type:	Business	Budget:	\$650,000
Construction Type:	IIIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Jim Winer
Construction Manager:	Brian Oliver-DPR
Aim Project Number:	2019-0312

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/1/2020
Disposition:	Declined	Date Completed:	7/7/2020

Status Statement

Note: New fire alarm system in Women's Basketball locker room

Review Comments:

1. No cover page
2. GT Standard – Construction type not identified
3. GT Standard – No occupancy Type
4. GT Standard – Scale 1/8"=1'0"
5. No wiring diagrams/ tree
6. No battery calculations noted on plan
7. Wire devices required per yellow book standard
8. No notation that alarm will be tied into Onyx Workstation with graphics and points
9. Onyx University paperwork must be supplied for installer
10. Confirm sprinkler points attached to alarm

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Permits Required:

1. Fire Alarm: 2020-PR-194
-