

---

## Plan Review Summary

---

### Building Information

Project Name:	Woodruff New Sprinkler System	Floor/Room #:	All
Building #:	116	Department:	GT Housing Facilities
Occupancy Type:	Dormitory	Budget:	\$200,000
Construction Type:	IIB	Type of Review:	Fire Suppression

---

### Project Management

Project Manager:	Prakhar Sahu
Architect/Engineer of Record:	Pro-Tec Fire
Construction Manager:	Matthew Alison
Aim Project Number:	

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/15/2020
Disposition:	Declined	Date Completed:	7/16/2020

---

### Status Statement

Note: New Fire Sprinkler System Installation; Connect to 4" Standpipe

### Review Comments:

1. The building is 5 stories and therefore NFPA 13R is not applicable. Please design and install the new fire sprinkler system in accordance with NFPA 13.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Permits Required:

1. Fire Suppression System
  2. Fire Alarm
-