
Plan Review Summary

Building Information

Project Name:	Women's Basketball Locker Room-Fire Alarm REVISION	Floor/Room #:	Full building
Building #:	73A	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$650,000
Construction Type:	IIB	Type of Review:	Fire Alarm-Revision

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Jim Winer
Construction Manager:	Biran Oliver-DPR
Aim Project Number:	2019-0312

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/15/2020
Disposition:	Declined	Date Completed:	7/16/2020

Status Statement

Note: New Fire Alarm System Installation

Review Comments:

1. Please provide smoke detectors and heat detectors in the following locations per GT Yellowbook Standard: SD -Toilets 112; SD – Team Lockers 107; HD – Showers 113; SD – Storage 114; SD – Laundry – 109; SD – Training 115.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Permits Required:

1. Fire Alarm
-