

---

## Plan Review Summary

---

### Building Information

Project Name:	Veterans Resource Center-Quad Cafe-REVISION	Floor/Room #:	Top Floor
Building #:	167A	Department:	Student Life
Occupancy Type:	Business	Budget:	\$400,000
Construction Type:	IIIA	Type of Review:	Fire Alarm-REVISION

---

### Project Management

Project Manager:	Thomas Schneider
Architect/Engineer of Record:	Kara Thomas
Construction Manager:	Anastasia Diavolitsis
Aim Project Number:	0157-2020

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/22/2020
Disposition:	Declined	Date Completed:	7/27/2020

---

### Status Statement

Note: New strobes, pull station

### Review Comments:

1. Wheelock devices not permitted on campus
2. Notification devices shall be white to conform with Yellow Book Standards

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Alarm
-