

---

## Plan Review Summary

---

### Building Information

Project Name:	Instructional Space-Howey Physics-Code Interpretation	Floor/Room #:	L 1-4 Sprinkler Infrastructure Contingency Spend
Building #:	081	Department:	Registrar
Occupancy Type:	Business	Budget:	\$165,000
Construction Type:	IIB	Type of Review:	Code Interpretation

---

### Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Todd Mowinski
Construction Manager:	Nicolas Palfrey
Aim Project Number:	0096-2018

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/31/2020
Disposition:	Consultation Provided - Submittal Required	Date Completed:	8/26/2020

---

### Status Statement

Note: Standpipe Drains and Testing Code Interpretation

### Review Comments:

1. The Standpipes shall be equipped with a 2 inch drain in accordance with NFPA 14.
2. I recommend extending the 2 proposed standpipe risers to the roof, so flow testing can be conducted on the roof.

### Plan / Shop Drawings Required:

1. Fire Suppression

### Permits Required:

1. Fire Suppression System
-