

---

## Plan Review Summary

---

### Building Information

---

Project Name:	Renovation of Instructional Space-Howey Physics Ancillary RISER	Floor/Room #:	4 stairwells
Building #:	081	Department:	E, H & S
Occupancy Type:	Business	Budget:	\$165,000
Construction Type:	IIB	Type of Review:	Fire Suppression

---

### Project Management

---

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Joshua Britt
Construction Manager:	Nicolas Palfrey
Aim Project Number:	0096-2018

---

### Reviewer Information

---

Reviewer Name:	Jake LeJeune	Date Received:	9/8/2020
Disposition:	Declined	Date Completed:	9/16/2020

---

### Status Statement

Note: Standpipe Installation

### Review Comments:

1. Please show compliance with the 2019 edition chapter 7 of NFPA 14 and provide hydraulic calculations.
2. Please show compliance with the 2019 edition chapter 7 of NFPA 14 and provide/indicate that 100psi residual pressure will be provided.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Permits Required:

1. Fire Suppression System
  2. Fire Alarm
-