

---

## Plan Review Summary

---

### Building Information

Project Name:	Women's Basketball Locker Room AS BUILTS	Floor/Room #:	1st Floor, Locker and Lounge Area
Building #:	73A	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$650,000
Construction Type:	IIB	Type of Review:	AS-Builts-Construction

---

### Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Jim Winer
Construction Manager:	Brian Oliver-DPR
Aim Project Number:	2019-0312

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	10/1/2020
Disposition:	Declined	Date Completed:	10/7/2020

---

### Status Statement

Note: Fire Alarm As-builts

### Review Comments:

1. Please submit the central testing report for GA Security indicating the that each device has been tested and the address number of each device is received at central station. The riser diagram shall have the device number so verification can be done.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
  2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)
-