
Plan Review Summary

Building Information

Project Name:	Russ Chandler Baseball Renovation Fire Suppression-REVISION	Floor/Room #:	
Building #:	168	Department:	Gt Design and Construction
Occupancy Type:	Business	Budget:	\$10M
Construction Type:	IIB	Type of Review:	Fire Suppression-REVISION

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Cheng-Li Wang
Construction Manager:	Jackie Avello
Aim Project Number:	2020-0359

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/10/2020
Disposition:	Declined	Date Completed:	11/11/2020

Status Statement

Note: New Fire Sprinkler System

Review Comments:

1. Previous comment dated 10/16/20 still exists: please provide manufacturer specifications for all equipment including but not limited to: piping, fire sprinkler heads, fittings, valves, etc.
2. Previous comment dated 10/16/20 still exists: please indicate if the elevator is traction or hydraulic and provide the fire sprinkler head at the top and bottom of the elevator shaft as required by NFPA 13.
3. Fire sprinkler coverage below the roll back doors will be required as required by NFPA 13.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Permits Required:

1. Demolition
 2. Construction / Interior Renovation
 3. Fire Suppression System
 4. Fire Alarm
-