
Plan Review Summary

Building Information

Project Name:	Fire Sprinkler Infrastructure-Cherry Emerson	Floor/Room #:	Site and Entire Building
Building #:	066	Department:	Click here to enter text.
Occupancy Type:	Business	Budget:	
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Jacobs(site) and SWI(Building)
Construction Manager:	Fenella Bryant
Aim Project Number:	0038-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/19/2020
Disposition:	Declined	Date Completed:	12/2/2020

Status Statement

Note: Fire Sprinkler System Design

Review Comments:

1. Two sets of Contractor plans and documents will need to be submitted for review as well.
2. There are Architecture pages and mechanical pages included in this submittal. Please remove them or provide a reason for their submittal with the fire protection plans.
3. Please provide Thrust block and restraint system details and calculations as required by NFPA 24 2019 edition.
4. Please submit a second copy of all documents with the plans. Only one set of hydraulic calculations and specifications were submitted. Also submit all manufacturer specifications of equipment that will be installed.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Permits Required:

1. Demolition
 2. Construction / Interior Renovation
 3. Fire Suppression System
 4. Fire Alarm
-