
Plan Review Summary

Building Information

Project Name:	Nanotech Chiller Replacement Crane Plan	Floor/Room #:	Chiller Room, ground floor
Building #:	181	Department:	Facilities
Occupancy Type:	Business	Budget:	\$1,525,091
Construction Type:	IIIB	Type of Review:	Logistics-Crane Plan

Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Sam Dahdah
Construction Manager:	Mark Wood
Aim Project Number:	0144-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/24/2020
Disposition:	Declined	Date Completed:	11/30/2020

Status Statement

Note: Crane Plan

Review Comments:

1. Provide recent inspection record for the crane and cable
2. Provide crane specifications
3. Provide "No Fly Zone"
4. Provide operators credentials including driver's license
5. Provide safety plan for protection of students, staff and visitors.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

2020-PR-307
