
Plan Review Summary

Building Information

Project Name:	Quantum Science Interaction & Kimchi Office Renovation	Floor/Room #:	2nd Floor/C204
Building #:	081	Department:	College of Science
Occupancy Type:	Business	Budget:	\$190,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Ngugi Mathu
Construction Manager:	Fenella Bryant
Aim Project Number:	0462-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	12/17/2020
Disposition:	Declined	Date Completed:	12/28/2020

Status Statement

Note: Addition of fire sprinkler heads for corridor window and Interaction room

Review Comments:

1. Please indicate if the corridor wall is a fire-rated wall. If so, it appears that the 2019 edition of NFPA 13, 9.3.15 for Sprinkler-Protected Glazing as an alternate to a required fire-rated wall or window assembly. Please show compliance with the 7 listed requirements or provide evidence that this code does not apply.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Permits Required:

1. Fire Suppression System
-