

Fire Safety

Plan Review Summary

Building Information			
Project Name:	East Housing Utilities Infrastructure-Phase 1(Area 1 Water)	Floor/Room #:	
Building #:	800	Department:	Housing & Residence Life
Occupancy Type:	Dormitory	Budget:	\$600,000
		Type of Review:	Construction-Site Plan
Project Management			
Project Manager:	Brad Morris		
Architect/Engineer of	Record: Vance Hall, RMF Engineering		
Construction Manage	r:		
Aim Project Number:	0384-2019		
	Reviewer Information		
Reviewer Name:	Jake LeJeune	Date Received:	9/23/2020
Disposition:	Approved	Date Completed:	9/30/2020

Status Statement

Note: 12" Water main tap into a 16" water main on North Ave; run 12" down along Techwood

General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

- 1. Fire Safety Office Project Kick-Off Meeting
- 2. Thrust Block Inspections
- 3. Underground Pressure Test
- 4. System Flush
- 5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Site Plan: 2020-SP-261