

Plan Review Summary

Building Information

Project Name:	Campus Center-Phase 2 Construction Trailer Permit	Floor/Room #:	
Building #:		Department:	Facilities-Design and Construction
Occupancy Type:	Business	Budget:	\$110M
Construction Type:	VB	Type of Review:	Construction-Temporary Structure

Project Management

Project Manager:	John DuConge
Architect/Engineer of Record:	Cooper Carry
Construction Manager:	Gilbane Building Company
Aim Project Number:	BOR-PPV-30-1801

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/2/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/4/2020

Status Statement

Note: Relocation of construction trailer for Phase 2

Review Comments:

1. Trailer shall be inspected after placement to verify fire safety conditions

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction: 2020-TS-146