

Plan Review Summary

Building Information

Project Name:	Russ Chandler Baseball Renovation-Temporary Structure	Floor/Room #:	Scaffolding
Building #:	168	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$10M
Construction Type:	IIB	Type of Review:	Temporary Structure

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Cheung-Li Wang
Construction Manager:	Jackie Avello
Aim Project Number:	2020-0359

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	10/13/2020
Disposition:	Approved	Date Completed:	11/4/2020

Status Statement

Note: Scaffolding; Temporary Structure

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Temporary Structure: 2020-TS-284
-

