
Plan Review Summary

Building Information

Project Name:	MS&E Curtis BSC Install	Floor/Room #:	1st Floor/1144B
Building #:	167	Department:	School of Physics
Occupancy Type:	Business	Budget:	\$6,000
Construction Type:	IB	Type of Review:	Construction

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Ngugi Mathu
Construction Manager:	Blake B
Aim Project Number:	0094-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	1/21/2021
Disposition:	Approved	Date Completed:	1/25/2021

Status Statement

Note: Install Bio-safety cabinet

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-009
-