

## Plan Review Summary

### Building Information

Project Name:	Boggs Transformer Replacement & Switchgear Improvements	Floor/Room #:	Entire Building
Building #:	103	Department:	Facilities Design and Construction
Occupancy Type:	Business	Budget:	\$4,600,000.00
Construction Type:	IIIA	Type of Review:	Construction

### Project Management

Project Manager:	Brian Clarke
Architect/Engineer of Record:	Dennis Carter
Construction Manager:	Kynthia Gaines
Aim Project Number:	0197-2020

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/25/2021
Disposition:	Approved	Date Completed:	3/8/2021

### Status Statement

Note: Transformer and switch gear

### Review Comments:

1. Approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation: 2021-CP-041