

## Plan Review Summary

### Building Information

Project Name:	Cherry Emerson-Fire Sprinkler Infrastructure	Floor/Room #:	Site and Entire Building
Building #:	066	Department:	Facilities Management & FSO
Occupancy Type:	Business	Budget:	\$1,300,000
Construction Type:	IIB	Type of Review:	Construction-REVISION

### Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Jacobs(site) and SWI (building)
Construction Manager:	Fenella Bryant
Aim Project Number:	0038-2020

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/4/2021
Disposition:	Approved	Date Completed:	3/22/2021

### Status Statement

Note: Fire Sprinkler Supply piping; Design documents

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System

### Permits Issued:

1. Construction / Interior Renovation: 2021-CP-049