

Plan Review Summary

Building Information

Project Name:	Howell Residence Hall-Summer 2021 Refresh Project	Floor/Room #:	All
Building #:	010	Department:	GT Housing
Occupancy Type:	Dormitory	Budget:	\$197,000
Construction Type:	IIIA	Type of Review:	Construction

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	ASD/Sky Design
Construction Manager:	Spencer Sheffield
Aim Project Number:	0113-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/23/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/7/2021

Review Comments:

1. Interior finish classifications are as follows: Wall and Ceiling-exit enclosures: A or B; lobbies and corridors: A or B; other spaces: A, B, or C. Floor: not less than II for nonsprinklered buildings.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-067