
Plan Review Summary

Building Information

Project Name:	Garten Lab Fit-Up-Pettit	Floor/Room #:	2nd Floor, Room 244
Building #:	095	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$600,000
Construction Type:	IIB	Type of Review:	Construction-REVISION

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	EYP/N&B
Construction Manager:	Thomas Schneider
Aim Project Number:	0096-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/15/2021
Disposition:	Approved	Date Completed:	5/5/2021

Status Statement

Note: NFPA 45 LAB

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-081
-