
Plan Review Summary

Building Information

Project Name:	First Center-AHU 8 Replacement	Floor/Room #:	1st Floor
Building #:	124	Department:	GT Office of the Arts
Occupancy Type:	Business	Budget:	\$300,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Federico Del Risco
Architect/Engineer of Record:	Matthew R. Sipes/RMF Engineering
Construction Manager:	Cristina Fannin
Aim Project Number:	0223-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/15/2021
Disposition:	Approved	Date Completed:	4/26/2021

Status Statement

Note: AHU 8 Replacement; new duct detector will require fire alarm permit

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-082
-