

---

## Plan Review Summary

---

### Building Information

Project Name:	Loading Dock Ceiling Repair-Ford E&ST	Floor/Room #:	L2/Loading Dock
Building #:	147	Department:	Facilities O&M
Occupancy Type:	Business	Budget:	\$25,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Ngugi Mathu
Construction Manager:	Cristina Fannin
Aim Project Number:	0059-2021

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/20/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/26/2021

---

### Status Statement

Note: Raise Ceiling at loading dock

### Review Comments:

1. Fire Sprinkler work will require a separate permit.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System

### Permits Issued:

1. Construction / Interior Renovation: 2021-CP-088
-