

---

## Plan Review Summary

---

### Building Information

|                    |  |                 |                       |
|--------------------|--|-----------------|-----------------------|
| Project Name:      | Montgomery Knight-Office 311 Chair Suite Refresh | Floor/Room #:   | 3rd                   |
| Building #:        | 101  | Department:     | Aerospace Engineering |
| Occupancy Type:    | Business   | Budget:         |                       |
| Construction Type: | IIB  | Type of Review: | Construction          |

---

### Project Management

|                               |                        |
|-------------------------------|------------------------|
| Project Manager:              | Polly Patton           |
| Architect/Engineer of Record: | Maria del Mar Ceballos |
| Construction Manager:         | Mitchell Shelton       |
| Aim Project Number:           | 0130-2021              |

---

### Reviewer Information

|                |              |                 |           |
|----------------|--------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received:  | 4/19/2021 |
| Disposition:   | Approved     | Date Completed: | 5/5/2021  |

---

### Status Statement

Note: INTERIOR FINISHES

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System
2. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation: 2021-CP-089
-