

---

## Plan Review Summary

---

### Building Information

Project Name:	Crecine Boiler Replacement-Campus Services Warehouse	Floor/Room #:	Mechanical Room
Building #:	882	Department:	Housing
Occupancy Type:	Dormitory	Budget:	\$652,043.00
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Bryan Kler
Construction Manager:	
Aim Project Number:	0455-2020

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/27/2021
Disposition:	Approved	Date Completed:	4/30/2021

---

### Status Statement

Note: Boiler Change-out

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation: 2021-CP-099
-