
Plan Review Summary

Building Information

Project Name:	West Village Dining Conversion	Floor/Room #:	1,2,3
Building #:	209	Department:	Tech Dining
Occupancy Type:	Business	Budget:	\$172,000
Construction Type:	IIA	Type of Review:	Construction

Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	ASD
Construction Manager:	Gay Construction
Aim Project Number:	0074-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/11/2021
Disposition:	Approved	Date Completed:	5/24/2021

Status Statement

Note: Renovation; Doors; interior finishes

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-106
-