

## Plan Review Summary

### Building Information

Project Name:	Administration & Carnegie Hot Water Boiler-Bradley	Floor/Room #:	Basement/Various
Building #:	074	Department:	Facilities
Occupancy Type:	Business	Budget:	\$700,000
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Greg Spiro
Architect/Engineer of Record:	Tim North
Construction Manager:	Jennifer Disotell
Aim Project Number:	0123-2021

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/18/2021
Disposition:	Approved	Date Completed:	6/3/2021

### Status Statement

Note: New Boiler replacement; fire-rated walls and 2hr. fire rated doors

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation: 2021-CP-115