
Plan Review Summary

Building Information

Project Name:	Food Pro Fume Hood-Food Processing Technology Research	Floor/Room #:	Ground/G61 ATAS Lab 1138
Building #:	159	Department:	SSD
Occupancy Type:	Business	Budget:	\$50,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	Timothy North
Construction Manager:	Matthew Hoerr
Aim Project Number:	0199-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/25/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/8/2021

Status Statement

Note: Fume Hood Replacement

Review Comments:

1. Please have the fume hood manufacturer specifications at time of inspection.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-127
-