Georgia Environmental Tech Health & Safety

Fire Safety

Plan Review Summary

Building Information			
Project Name:	Love Gender Neutral Restroom	Floor/Room #:	1
Building #:	144	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$45,000
Construction Type:		Type of Review:	Construction
Project Management			
Project Manager:	CATUE SA		
Architect/Engineer of Record: Amber Chellis-Omedo			
Construction Manager: Mitchell Shelton			
Aim Project Number:	040-2020		
Reviewer Information			
Reviewer Name:	Jake LeJeune	Date Received:	5/26/2021
Disposition:	Approved	Date Completed:	6/16/2021
Note: New Restroom General Note: 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work			
Plan / Shop Drawings Required:			
 Fire Suppressi Fire Alarm 			
Inspections Required:			
 Fire Safety Office Project Kick-Off Meeting 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.) 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.) 			
Permits Required:			

- 1. Fire Suppression System
- 2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-129