Plan Review Summary

151 Sixth Street, Suite 341 Atlanta, Georgia 30332 404-894-FIRE (3473)

Georgia Environmental Tech Health & Safety

Fire Safety

Building Information			
Project Name:	Clough Suite 365 Neuroscience	Floor/Room #:	3rd floor/365
Building #:	166	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$233,000
Construction Type:	IB	Type of Review:	Construction
Project Management			
Project Manager:	Ngugi Mathu		
Architect/Engineer of	Record: Corgan		
Construction Manager: Thomas Schneider			
Aim Project Number:	0256-2021		
Reviewer Information			
Reviewer Name:	Jake LeJeune	Date Received:	5/26/2021
Disposition:	Approved	Date Completed:	6/10/2021
Status Statement Note: 6 New Offices General Note:			
General Note.			
1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request			
Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work			
Plan / Shop Drawings Required:			
1. Fire Suppression			
2. Fire Alarm	s lette		
Inspections Required:			
1. Fire Safety Office Project Kick-Off Meeting			
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed			
in, etc.) 3 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete			

 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

- 1. Construction / Interior Renovation
- 2. Fire Suppression System
- 3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-130