

Plan Review Summary

Building Information

Project Name:	CNES-Lab 146 Fit-Out	Floor/Room #:	1st Floor/Room 146
Building #:	199	Department:	Guggebheim School Aero Engineering
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Greg Spiro
Architect/Engineer of Record:	Integrated Engineering Services-Mark Bertz
Construction Manager:	Cristina Fannin
Aim Project Number:	0233-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/17/2021
Disposition:	Approved	Date Completed:	7/6/2021

Status Statement

Note: Gas piping system; flammable liquids; exterior; Class C lab, NFPA 45

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-154