
Plan Review Summary

Building Information

Project Name:	TSRB-S16 Renovation-Larry Heck	Floor/Room #:	Basement-S16B
Building #:	175	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$47,779
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	Molly California-Dyer Brown & Associates, Inc.
Construction Manager:	Jennifer Disotell
Aim Project Number:	0317-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/6/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	7/20/2021

Status Statement

Note: Renovation

Review Comments:

1. There is an existing dead-end corridor extending more than 50 feet that cannot be corrected without causing additional hazards. Due to this issue, a sign will need to be created to place on the double doors going into this corridor indicating DEAD-END/NO EXIT.

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-168
-