
Plan Review Summary

Building Information

Project Name:	SE&MR Lab-Liquid Propellant Storage	Floor/Room #:	114
Building #:	149	Department:	Aerospace Engineering
Occupancy Type:	Business	Budget:	\$5,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Greg Spiro
Architect/Engineer of Record:	Mark Berz
Construction Manager:	
Aim Project Number:	0421-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/19/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	8/3/2021

Status Statement

Note: Storage, use, handling of liquid propellant

Review Comments:

1. The propellant liquid is to be stored in a secured/locked magazine container near an exit as the documents submitted indicate; cannot be stored in an environment with a prolonged ambient temperature of 200 F.

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation: 2021-CP-175
-