
Plan Review Summary

Building Information

Project Name:	CRC Roof Investigation & Solar Panel Removal	Floor/Room #:	Exterior, Roof
Building #:	160	Department:	Facilities
Occupancy Type:	Business	Budget:	\$600,000
Construction Type:	IIB	Type of Review:	Elevator/Lift

Project Management

Project Manager:	Mark Wood
Architect/Engineer of Record:	Chris Giffin
Construction Manager:	Mark Wood
Aim Project Number:	0085-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/12/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	7/20/2021

Status Statement

Note: Elevator/Lift

Review Comments:

1. The elevator/lift will be required a permit from the State Fire Marshal's Office, Elevator Section before any work or use can begin.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Elevator/lift: 2021-EV-171
-