

---

## Plan Review Summary

---

### Building Information

Project Name:	Ford ES&T-Lang Lab Fit-Up	Floor/Room #:	3rd floor-3131 & 3139
Building #:	147	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$209,000
Construction Type:	IIIB	Type of Review:	Fire Alarm

---

### Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Warren Epstein Architects
Construction Manager:	Cristina Fannin
Aim Project Number:	0406-2020

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/4/2021
Disposition:	Approved	Date Completed:	2/5/2021

---

### Status Statement

Note: New Strobe on ceiling, wax coated heads

### Review Comments:

1. Approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm: 2021-FA-022
-