
Plan Review Summary

Building Information

Project Name:	Baker-Room 350 Modifications-Fire Alarm	Floor/Room #:	350
Building #:	099	Department:	GTRI
Occupancy Type:	Business	Budget:	\$3,000
Construction Type:	IIIA	Type of Review:	Fire Alarm

Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	Concord Project Consulting-Dennis Carter
Construction Manager:	Anne Russell, GTRI
Aim Project Number:	0018-2021

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	3/5/2021
Disposition:	Approved	Date Completed:	3/15/2021

Status Statement

Note: Add strobe, move strobe

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2021-FA-053
-