

---

## Plan Review Summary

---

### Building Information

Project Name:	COC Fire Alarm Upgrade	Floor/Room #:	ALL floors
Building #:	050	Department:	Facilities-U&E
Occupancy Type:	Business	Budget:	\$413,202
Construction Type:	IIB	Type of Review:	Fire Alarm

### Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	N/A
Construction Manager:	Fenella Bryant
Aim Project Number:	0225-2021

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/3/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/14/2021

### Status Statement

Note: New Fire Alarm System; Notifier, Onyx

### Review Comments:

1. Please provide a horn/strobe on the roof, exterior penthouse wall above the pull station.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm: 2021-FA-136
-