

---

## Plan Review Summary

---

### Building Information

---

Project Name:	Groseclose Academic Office Addition Fire Alarm	Floor/Room #:	1st
Building #:	056	Department:	School of Industrial & Systems Engineering
Occupancy Type:	Business	Budget:	\$50,000
Construction Type:	IIB	Type of Review:	Fire Alarm

---

### Project Management

---

Project Manager:	
Architect/Engineer of Record:	Maria Ceballos
Construction Manager:	Mitchell Shelton
Aim Project Number:	0267-2021

---

### Reviewer Information

---

Reviewer Name:	Jake LeJeune	Date Received:	6/10/2021
Disposition:	Approved	Date Completed:	6/23/2021

---

### Status Statement

Note: 3 NEW STROBES

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm: 2021-FA-145
-