

---

## Plan Review Summary

---

### Building Information

Project Name:	Crecine Residence Hall Renovation Fire Alarm	Floor/Room #:	All
Building #:	131	Department:	Housing
Occupancy Type:	Dormitory	Budget:	\$800,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

---

### Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Meredith Black
Construction Manager:	
Aim Project Number:	0110-2021

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/10/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/23/2021

---

### Status Statement

Note: New Horn/strobes

### Review Comments:

1. The plans submitted were not original size. The scale was not correct. The visual appliances shall be in accordance with NFPA 72 regarding candela requirements.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm: 2021-FA-146
-