
Plan Review Summary

Building Information

Project Name:	Clough Suite 365 Neuroscience Fire Alarm	Floor/Room #:	Suite 365
Building #:	166	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$1,400
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Tanya Richard-Corgan
Construction Manager:	Thomas Schneider
Aim Project Number:	0256-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/6/2021
Disposition:	Approved w/ Additional Requirements	Date Completed:	7/19/2021

Status Statement

Note: Fire Alarm Devices

Review Comments:

1. Smoke detectors are required in the corridor per GT Yellowbook

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2021-FA-167
-