
Plan Review Summary

Building Information

Project Name:	Digital Fab Loading Dock Fire Suppression	Floor/Room #:	Loading Dock
Building #:	158	Department:	Facilities Design & Construction
Occupancy Type:	Business	Budget:	\$3,500
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Dinah Diaz
Architect/Engineer of Record:	Ed Chapman
Construction Manager:	Allen Roller
Aim Project Number:	0205-21/0468-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	1/26/2021
Disposition:	Approved	Date Completed:	1/29/2021

Status Statement

Note: Add 4 new Sidewall sprinkler heads

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System: 2021-FS-011
-