
Plan Review Summary

Building Information

Project Name:	Pettit Cleanroom Bay 4&5 Sprinkler Update	Floor/Room #:	Basement/Clean room floor
Building #:	095	Department:	IEN
Occupancy Type:	Business	Budget:	\$600,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	Ronnie Beam
Construction Manager:	Thomas Schneider
Aim Project Number:	0042-2021

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	2/9/2021
Disposition:	Approved	Date Completed:	2/24/2021

Status Statement

Note: Ord. II Hazard Fire Sprinkler System

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System: 2021-FS-028
-