
Plan Review Summary

Building Information

Project Name:	Sprinkler Riser Room-GT Ferst Theater	Floor/Room #:	Storage area/Work shop/Riser room
Building #:	124	Department:	
Occupancy Type:	Business	Budget:	
Construction Type:	IIIA	Type of Review:	Fire Suppression

Project Management

Project Manager:
Architect/Engineer of Record: Frederico Del Rico
Construction Manager:
Aim Project Number:

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/25/2021
Disposition:	Approved	Date Completed:	3/8/2021

Status Statement

Note: Sprinkler

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System: 2021-FS-043
-