Georgia Environmental Tech Health & Safety

Plan Review Summary

Building Information			
Project Name:	CARE Expansion-Smithgall	Floor/Room #:	108,109
Building #:	123	Department:	Student Life
Occupancy Type:	Business	Budget:	\$51,000
Construction Type:	IIB	Type of Review:	Fire Suppression
Project Management			
Project Manager:	Brad Morris		
Architect/Engineer of	f Record: Becky Williams, HLG Studio		
Construction Manage	er: Mark Harwell, Cork Howard		
Aim Project Number:	0197-2020		
Reviewer Information			
Reviewer Name:	Jake LeJeune	Date Received:	3/23/2021
Disposition:	Approved	Date Completed:	3/29/2021
Status Statement			

Note: Add/relocate 2 fire sprinkler heads

Inspections Required:

- 1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Suppression System: 2021-FS-065